

**CITY OF FLORA**  
**GAS SERVICE GUIDELINES**

1. Gas meters must remain plumb and level.
2. The gas from the house must be one inch (1") black iron pipe.
3. Three-quarter inch (3/4") diameter pipe is allowed for run's of thirty feet (30') or less to the heating plant or first major appliance.
4. If it is through concrete or brick it must be in a plastic sleeve, caulking will be used between the gas line and the sleeve.
5. There must be a valve with six feet (6') of each gas appliance or unit.
6. Heating plants and water heaters shall be connected to gas piping with black iron pipe or AGA listed flexible connector.
7. Iron pipe must extend to within one foot (1') of the appliance and the pipe supported securely.
8. All gas lines outside should b painted
9. A pressure test will be conducted by a city representative before the gas is turned on. To schedule a time for test and turn on, call 618-662-8313.